

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:59 am

PWS ID: UTAH09085 **Name:** PAUNSAUGUNT CLIFFS SSD
Legal Contact: PAUNSAUGUNT CLIFFS SSD **Rating:** Not Approved
MYRON BEN NEILSON **Rating Date:** 12/10/2008
Address: PO BOX 620 **Activity Status:** Active
HATCH, UT 84735
Phone Number: 435-735-4019
City Served (Area):
County: GARFIELD COUNTY
System Type: Community **Last Inv Update:** 10/05/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 06/03/2009 **Total Dsgn Cap:**
Population: 50 **Surveyor:** JOHN L CHARTIER **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	NEILSON, MYRON BEN		435-735-4364	435-735-4385	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	134
Commercial	Unknown	0	1
			135 Total Svc Connections

Storage

Total Storage: 330,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	PAUNSAUGUNT TANK	Reservoir	330,000 GAL		7100	A	NO

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	PAUNSAUGUNT WELL	Active	WL			150 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.